



土被り早見表 (4)

適用条件

1. 溝型
2. 砂基礎
3. 土の単位重量 $\gamma = 18\text{kN/m}^3$
4. 活荷重：T荷重

単位：m

呼び径	1種		2種	1種		2種	1種		2種
	60°		60°	90°		90°	120°		120°
	下限	上限	上限	下限	上限	上限	下限	上限	上限
200		5.3	7.8		6.6	9.4		7.6	10.8
250	0.6	4.1	6.3		5.2	7.6		6.1	8.8
300	0.7	3.5	5.6		4.6	6.9		5.4	8.0
350	0.8	3.3	5.2	0.6	4.3	6.4		6.1	7.4
400	0.8	3.2	5.4	0.6	4.2	6.7		4.9	7.7
450	0.8	3.0	5.4	0.6	4.0	6.7		4.8	7.7
500	0.9	2.9	5.6	0.6	3.9	6.9		4.7	7.9
600	0.9	2.8	5.6	0.7	3.8	6.9	0.6	4.5	7.9
700	1.0	2.5	5.3	0.8	3.5	6.5	0.6	4.3	7.5
800	1.1	2.3	5.0	0.8	3.4	6.2	0.6	4.1	7.2
900	1.2	2.1	4.9	0.8	3.2	6.0	0.6	4.0	7.0
1000	1.3	2.0	4.7	0.8	3.1	5.9	0.7	3.9	6.8
1100			4.5	0.9	3.0	5.7	0.7	3.7	6.6
1200			4.3	0.9	2.8	5.4	0.7	3.5	6.3
1350			4.0	1.0	2.5	5.1	0.8	3.2	6.0
1500			3.8	1.1	2.4	4.9	0.8	3.1	5.7
1650			3.7	1.2	2.2	4.7	0.8	3.0	5.5
1800			3.6	1.2	2.1	4.6	0.9	3.0	5.4
2000			3.4	1.3	2.0	4.4	0.9	2.9	5.2
2200			3.3	1.4	1.9	4.3	0.9	2.8	5.1
2400			3.2	1.4	1.7	4.2	0.9	2.8	5.0
2600			3.1	1.5	1.7	4.1	0.9	2.8	4.9
2800			3.1	1.4	1.8	4.1	0.9	2.8	4.9
3000			3.1	1.4	1.9	4.1	0.9	2.8	4.8

※ 空欄については、別途お問い合わせ下さい。
(道路土工による下限値は0.5)